

Matlacha/Pine Island Fire Control District
RFP Station 3 Generator: Q & A
May 16, 2025, 10:00 am
Pine Island Fire Station 3, 14861 Stringfellow Rd., Bokeelia

Call to Order: Chief Mickuleit called the meeting to order at 10:00 am.

Overview of Request for Proposal: Chief Mickuleit gave a brief overview of the project and opened the floor to questions from the attendees.

Questions and Answers:

1. Time frame: The district would like to move this project along as quickly as possible.
2. Preference on make of generator: No preference on make, 100kw, 400-amp switch, 500-gallon fuel tank. The district would like to see a 7-day run time.
3. Sound enclosure: currently level 1, no need to increase.

The attendees and administration walked the site and were given the opportunity to take photos of the current set up.

Public Comment:

None

Adjournment: Meeting adjourned at 11:00 am.